

! " # ! \$ % " & ' ! " ()

264-DF-6087-A-005-A	N/A	1/22/2021	1/25/2021	A1A0791-01	Lead	0.358	0.2	15	ppb
264-DF-3762-A-005-A	Hallway by Classr !	1/22/2021	1/25/2021	A1A0791-02	Lead	ND	0.2	15	ppb
264-DF-3773-A-005-A	Ca"e# r\$#!	1/22/2021	1/25/2021	A1A0791-03	Lead	ND	0.2	15	ppb
264-DF-3767-A-005-A	Hallway by C%# d\$a&	1/22/2021	1/25/2021	A1A0791-04	Lead	ND	0.2	15	ppb
264-DF-3784-A-005-A	Hallway by ' y(s L)*er	1/22/2021	1/25/2021	A1A0791-05	Lead	ND	0.2	15	ppb
264-DF-3805-A-005-A	Hallway by Classr !	1/22/2021	1/25/2021	A1A0791-06	Lead	0.326	0.2	15	ppb
264-DF-3808-NA-005-A	Classr !	1/22/2021	1/25/2021	A1A0791-07	Lead	0.769	0.2	15	ppb
264-DF-3761-NA-005-A	Classr !	1/22/2021	1/25/2021	A1A0791-08	Lead	1.35	0.2	15	ppb
264-DF-5701-NA-005-A	+#a""r !	1/22/2021	1/25/2021	A1A0791-09	Lead	1.02	0.2	15	ppb
264-DF-3778-NA-005-A	Fa)%l#y	1/22/2021	1/25/2021	A1A0791-10	Lead	0.834	0.2	15	ppb