

Portland Public Schools
 Lead Based Sample Results
 Initial Student Sample Data
 Supplemental (Elementary) Test *

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
143-DF-4590-N/A-004-A	SES Classroom (211)	8/27/2021	8/30/2021	A1H0917-05	Lead	0.28	0.2	15	!!"
143-DF-4584-N/A-004-A	SES Classroom (213)	8/27/2021	8/30/2021	A1H0917-06	Lead	0.912	0.2	15	!!"
143-DF-4581-N/A-004-A	SES Classroom (214)	8/27/2021	8/30/2021	A1H0917-07	Lead	0.429	0.2	15	!!"