

Portland Public Schools
 Lead #ate! Samplin\$ Results
 Initial %lus" Sample Data
 Cesa! C"avez &' (Sc"ool ' Test)

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	nits
182-DF-5807-N/A-005-A	Health Room	8/25/2021	08/26/2021	A1H0836-16	Lead	1.29	0.2	15	ppb
182-DF-2929-A-005-A	Hallwa !02"#	8/25/2021	08/26/2021	A1H0836-17	Lead	ND	0.2	15	ppb
182-DF-2938-A-005-A	Hallwa !2"8#	8/25/2021	08/26/2021	A1H0836-18	Lead	0.221	0.2	15	ppb
182-DF-5808-N/A-005-A	Fa\$%lt Re&o%'\$e 1"8	8/25/2021	08/26/2021	A1H0836-19	Lead	0.896	0.2	15	ppb
182-DF-5806-N/A-005-A	()t\$he*	8/25/2021	08/26/2021	A1H0836-20	Lead	ND	0.2	15	ppb
182-DF-2928-A-005-A	Hallwa !131#	8/25/2021	08/26/2021	A1H0836-21	Lead	ND	0.2	15	ppb
182-DF-29""-A-005-A	Hallwa !22"#	8/25/2021	08/26/2021	A1H0836-22	Lead	ND	0.2	15	ppb
182-DF-2930-A-005-A	Hallwa !15"#	8/25/2021	08/26/2021	A1H0836-23	Lead	ND	0.2	15	ppb