

Portland Public Schools
Lead Testing Sampling Results
Initial Plus Sample Data
Creston Elementary School - Test 1

| Sample Identification # | Location | Date/Time Collected | Date Analyzed | Lab ID | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 243-DF-2273-N/A-006-A | Kitchen | 12/11/2020 | 12/29/2020 | AOL0483-07 | Lead | 0.229 | 0.2 | 15 | ppb |
| 243-DF-5361-A-006-A | Hall #103 | 12/11/2020 | 12/29/2020 | AOL0483-08 | Lead | ND | 0.2 | 15 | ppb |
| 243-DF-5771-N/A-006-A | #118 | 12/11/2020 | 12/29/2020 | AOL0483-09 | Lead | 0.211 | 0.2 | 15 | ppb |
| 243-DF-5773-N/A-006-A | #1 | 12/11/2020 | 12/29/2020 | AOL0483-10 | Lead | 0.205 | 0.2 | 15 | ppb |
| 243-DF-5772-A-006-A | Hall (C&N) | 12/11/2020 | 12/29/2020 | AOL0483-11 | Lead | ND | 0.2 | 15 | ppb |
| 243-DF-5770-N/A-006-A | N) | 12/11/2020 | 12/29/2020 | AOL0483-12 | Lead | ND | 0.2 | 15 | ppb |

* +HA Action Level - 15ppb