


! "
 # ! \$
 % "
 & ! ' " ()



257-DF-6009-N/A-004-A	Staff Room (106)	8/27/2021	8/31/2021	A1H0917-13	Lead	1.08	0.2	15	!
257-DF-6012-N/A-004-A	Head# Room (Room 2)	8/27/2021	8/31/2021	A1H0917-14	Lead	0.764	0.2	15	!
257-DF-6011-N/A-004-A	Staff Room (5)	8/27/2021	8/31/2021	A1H0917-15	Lead	1.3	0.2	15	!
257-DF-6010-N/A-004-A	Staff Room (6)	8/27/2021	8/31/2021	A1H0917-16	Lead	0.827	0.2	15	!
257-DF-3706-N/A-004-A	Att Room	8/27/2021	8/31/2021	A1H0917-17	Lead	0.528	0.2	15	!
257-DF-3708-N/A-004-A	Att#e+	8/27/2021	8/31/2021	A1H0917-18	Lead	3.24	0.2	15	!
257-DF-6007-N/A-004-A	Staff Room (121)	8/27/2021	8/31/2021	A1H0917-19	Lead	1.2	0.2	15	!