

262-DF-1674-A-006-A	Hallway (122)	9/10/2020	9/15/2020	A0I0302-01	Lead	ND	0.2	15	ppb
262-DF-1667-A-006-A	Hallway (130)	9/10/2020	9/15/2020	A0I0302-02	Lead	1.35	0.2	15	ppb
262-DF-1699-A-006-A	Clasificación # 141	9/10/2020	9/15/2020	A0I0302-03	Lead	5.97	0.2	15	ppb
262-DF-1696-A-006-A	Casos de	9/10/2020	9/15/2020	A0I0302-04	Lead	ND	0.2	15	ppb
262-DF-16' 4-N/A-006-A	(%) * e+	9/10/2020	9/15/2020	A0I0302-05	Lead	4.31	0.2	15	ppb
262-DF-1676-A-006-A	Hallway (211)	9/10/2020	9/15/2020	A0I0302-06	Lead	ND	0.2	15	ppb
262-DF-5913-A-006-A	Hallway (204)	9/10/2020	9/15/2020	A0I0302-07	Lead	ND	0.2	15	ppb
262-DF-1677-A-006-A	Hallway (239)	9/10/2020	9/15/2020	A0I0302-08	Lead	ND	0.2	15	ppb
262-DF-5777-N/A-006-A	Clasificación # 153	9/10/2020	9/15/2020	A0I0302-09	Lead	0.792	0.2	15	ppb
262-DF-166' -A-006-A	Hallway (151)	9/10/2020	9/15/2020	A0I0302-10	Lead	ND	0.2	15	ppb
262-DF-57' 5-N/A-006-A	Clasificación # 140	9/10/2020	9/15/2020	A0I0302-11	Lead	10.3	0.2	15	ppb
262-DF-57' 4-N/A-006-A	, %a\$\$ - "" #	9/10/2020	9/15/2020	A0I0302-12	Lead	4.00	0.2	15	ppb