

180-DF-5811-N/A-005-A	Health Room	08/12/2021	08/24/2021	A1H0403-26	Lead	1.90	0.2	15	ppb
180-DF-2975-A-005-A	Hall a!	08/12/2021	08/24/2021	A1H0403-27	Lead	ND	0.2	15	ppb
180-DF-5810-N/A-005-A	"la##\$oom	08/12/2021	08/24/2021	A1H0403-28	Lead	1.12	0.2	15	ppb
180-DF-5815-N/A-005-A	"la##\$oom	08/12/2021	08/24/2021	A1H0403-29	Lead	0.997	0.2	15	ppb
180-DF-5814-N/A-005-A	"la##\$oom	08/12/2021	08/24/2021	A1H0403-30	Lead	1.23	0.2	15	ppb
180-DF-5813-N/A-005-A	"la##\$oom	08/12/2021	08/24/2021	A1H0403-31	Lead	1.31	0.2	15	ppb
180-DF-3020-N/A-005-A	Hall a!	08/12/2021	08/24/2021	A1H0403-32	Lead	ND	0.2	15	ppb
180-DF-5812-N/A-005-A	"la##\$oom	08/12/2021	08/24/2021	A1H0403-33	Lead	1.22	0.2	15	ppb
180-DF-2926-A-005-A	"a%ete\$a	08/12/2021	08/24/2021	A1H0403-34	Lead	0.347	0.2	15	ppb
180-DF-2274-N/A-005-A	' &t (he)	08/12/2021	08/23/2021	A1H0403-35	Lead	46.3	0.2	15	ppb