

Portland Public Schools
Lead Sampling Results
Initial Sample Data
Creative Science School & Test

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
240-DF-5457-A-005	Hallway (Classroom 9)	7/14/2021	07/15/2021	A1G0373-01	Lead	ND	0.2	15	µg/l
240-DF-5951-N/A-005	Classroom	7/14/2021	07/15/2021	A1G0373-02	Lead	1.0	0.2	15	µg/l
240-DF-5950-N/A-005	Classroom	7/14/2021	07/15/2021	A1G0373-03	Lead	ND	0.2	15	µg/l
240-DF-5470-A-005	Classroom	7/14/2021	07/15/2021	A1G0373-04	Lead	ND	0.2	15	µg/l
240-DF-545'-A-005	Hallway (Classroom 9)	7/14/2021	07/15/2021	A1G0373-05	Lead	ND	0.2	15	µg/l
240-DF-543'-A-005	Hallway (Classroom 14)	7/14/2021	07/15/2021	A1G0373-06	Lead	ND	0.2	15	µg/l
240-DF-5949-N/A-005	Classroom	7/14/2021	07/15/2021	A1G0373-07	Lead	0.570	0.2	15	µg/l