

Portland Public Schools
 Lead # Date Sample Results
 Initial Plus Sample Data
 Rosa Parks Elementary (Test)

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
175-DF-2906-A-004-A	Hallway (Resource Room)	8/25/2021	08/26/2021	A1H0836-05	lead	< 2	0.2	15	µg/L
175-DF-2916-A-004-A	Hallway (Resource Room)	8/25/2021	08/26/2021	A1H0836-06	lead	< 2	0.2	15	µg/L
175-DF-2893-A-004-A	Hallway (Resource Room)	8/25/2021	08/26/2021	A1H0836-07	lead	< 2	0.2	15	µg/L
175-DF-2953-1/A-004-A	Restroom	8/25/2021	08/26/2021	A1H0836-08	lead	2.20	0.2	15	µg/L
175-DF-5799-1/A-004-A	Restroom	8/25/2021	08/26/2021	A1H0836-09	lead	0.257	0.2	15	µg/L