

Portland Public School I

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
186 DF1982A 004 A	Hallway(Classroom104)	7/27/2022	7/29/2022	A2G076304	Lead	ND	0.200	15	ppb
186 DF1984A 004 A	Hallway(Cafeteria)	7/27/2022	7/29/2022	A2G076303	Lead	ND	0.200	15	ppb
186 DF1988N/A 004 A	Kindergarten109	7/27/2022	8/1/2022	A2G076305	Lead	4.78	0.222	15	ppb
186 DF1989N/A 004 A	Kindergarten110	7/27/2022	8/1/2022	A2G076306	Lead	6.63	0.222	15	ppb
186 DF1992A 004 A	Hallway(Classroom207)	7/27/2022	7/29/2022	A2G076307	Lead	ND	0.200	15	ppb
186 DF1993A 004 A	Hallway(Classroom201)	7/27/2022	7/29/2022	A2G076301	Lead	ND	0.200	15	ppb
186 DF6136N/A 004 A	Kitchen	7/27/2022	7/29/2022	A2G076302	Lead	0.592	0.222	15	ppb
186 DF6141N/A 004 A	StaffRoom	7/27/2022	7/29/2022	A2G076308	Lead	3.09	0.200	15	ppb