

Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cleveland Site - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
213DF1107A 005A	Cafeteria	9/2/2022	9/7/2022	A2100601	Lead	ND	0.200	0.200	ppb
213DF1113A 005A	Hallway(238)	9/2/2022	9/7/2022	A2100602	Lead	ND	0.200	0.200	ppb
213DF1114A 005A	Hallway(281)	9/2/2022	9/7/2022	A2100603	Lead	ND	0.200	0.200	ppb
213DF1118A 005A	Hallway(238)	9/2/2022	9/7/2022	A2100604	Lead	ND	0.200	0.200	ppb
213DF1120A 005A	LifeSkillRoom	9/2/2022	9/7/2022	A2100605	Lead	1.98	0.200	0.200	ppb
213DF1121A 005A	Hallway(125)	9/2/2022	9/7/2022	A2100605	Lead	ND	0.200	0.200	ppb
213DF1123A 005A	Hallway(238)	9/2/2022	9/7/2022	A2100606	Lead	ND	0.200	0.200	ppb
213DF1126A 005A	Hallway(308)	9/2/2022	9/7/2022	A2100607	Lead	ND	0.200	0.200	ppb
213DF1131A 005A	Hallway(231/233)	9/2/2022	9/7/2022	A2100608	Lead	ND	0.200	0.200	ppb
213DF1132A 005A	Hallway(325)	9/2/2022	9/7/2022	A2100609	Lead	ND	0.200	0.200	ppb
213DF1135A 005A	Hallway(225)	9/2/2022	9/7/2022	A2100600	Lead	ND	0.200	0.200	ppb
213DF1190A 005A	Hallway(325)	9/2/2022	9/7/2022	A2100601	Lead	ND	0.200	0.200	ppb
213DF1193A 005A	Hallway(308)	9/2/2022	9/7/2022	A2100602	Lead	ND	0.200	0.200	ppb
213DF587A 005A	Gymnasium	9/2/2022	9/7/2022	A2100603	Lead	ND	0.200	0.200	ppb
213DF587A 005A	Hallway(218B)	9/2/2022	9/7/2022	A2100604	Lead	ND	0.200	0.200	ppb
213DF588A 005A	CulinaryArts	9/2/2022	9/7/2022	A2100606	Lead	0.249	0.200	0.200	ppb

*OHAActionLevel= 15ppb