

**Portland Public Schools
Lead WdPuWdPPuWIs**

Green Thumb Site - Test

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detect on Limit	PPS Action Level*	Units
305-DF-6122-N/A-005-A	Portable 3	12/1/2022	12/5/2022	A2L0132-01	Lead	1.33	0.2	15	ppb
305-DF-6123-N/A-005-A	Portable 4	12/1/2022	12/5/2022	A2L0132-02	Lead	0.830	0.2	15	ppb
305-DF-6124-N/A-005-A	Portable 5	12/1/2022	12/5/2022	A2L0132-03	Lead	0.601	0.2	15	ppb
305-DF-6125-N/A-005-A	Portable 6	12/1/2022	12/5/2022	A2L0132-04	Lead	1.23	0.2	15	ppb
305-DF-6126-N/A-005-A	Portable 7	12/1/2022	12/5/2022	A2L0132-05	Lead	1.68	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb