

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Da Vinci - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
365-DF-6014-N/A-006-A	Staff Room	8/11/2022	8/16/2022	A2H0474-01	Lead	1.98	0.2	15	ppb

\*OHA Action Level = 15ppb