

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Capitol Hill Site - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
144 DF 3945 A 004 A	Hallway (Classroom 102)	7/27/2022	7/29/2022	A2G0760 08	Lead	ND	0.200	15	ppb
144 DF 3952 A 004 A	Hallway (Custodian)	7/27/2022	7/29/2022	A2G0760 04	Lead	ND	0.200	15	ppb
144 DF 3954 A 004 A	Hallway (Gym)	7/27/2022	7/29/2022	A2G0760 01	Lead	ND	0.200	15	ppb
144 DF 3956 A 004 A	Hallway (Classroom 111)	7/27/2022	7/29/2022	A2G0760 07	Lead	ND	0.200	15	ppb
144 DF 3960 A 004 A	Cafeteria	7/27/2022	7/29/2022	A2G0760 02	Lead	ND	0.200	15	ppb
144 DF 3967 A 004 A	Hallway (Classroom 200)	7/27/2022	7/29/2022	A2G0760 05	Lead	ND	0.200	15	ppb
144 DF 6020 N/A 004 A	Kitchen	7/27/2022	7/29/2022	A2G0760 03	Lead	0.459	0.200	15	ppb
144 DF 6021 N/A 004 A	Staff Room	7/27/2022	7/29/2022	A2G0760 06	Lead	0.733	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1