

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Cleveland - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
213-DF-5876-A-006-A	Gymnasium (Upstairs)	10/19/2022	10/21/2022	A2J0602-01	Lead	ND	0.2	15	ppb

*OHA Action Level = 15ppb