

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Irvington Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
259 DF3841 A 005 A	Hallway (102)	9/16/2022	9/19/2022	A2I0504 01RE1	Lead	ND	0.200	15	ppb
259 DF3847 A 005 A	Hallway (105)	9/16/2022	9/21/2022	A2I0504 02	Lead	ND	0.222	15	ppb
259 DF3858 A 005 A	Hallway (87)	9/16/2022	9/19/2022	A2I0504 03RE1	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1