

174 DF 1866 A 006 A	Hallway (D116)	7/28/2022	8/2/2022	A2G0807 01	Lead	ND	0.200	15	ppb
174 DF 1887 A 006 A	Hallway (Gymnasium)	7/28/2022	8/2/2022	A2G0807 09	Lead	ND	0.200	15	ppb
174 DF 2000 A 006 A	Wood Shop	7/28/2022	8/2/2022	A2G0807 10	Lead	ND	0.200	15	ppb
174 DF 6023 N/A 006 A	Staff Room	7/28/2022	8/2/2022	A2G0807 02	Lead	0.432	0.200	15	ppb
174 DF 6024 A 006 A	Hallway (Cafeteria)	7/28/2022	8/2/2022	A2G0807 06	Lead	ND	0.200	15	ppb
174 DF 6025 N/A 006 A	Kitchen	7/28/2022	8/2/2022	A2G0807 07	Lead	1.19	0.200	15	ppb
174 DF 6027 N/A 006 A	Staff Room (G241)	7/28/2022	8/2/2022	A2G0807 14	Lead	0.823	0.200	15	ppb
174 DF 6028 N/A 006 A	Staff Room (G220)	7/28/2022	8/2/2022	A2G0807 12	Lead	0.875	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1