

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Kenton - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
168-DF-3015-A-003-A	Hallway (Courtyard 1)	5/20/2022	5/31/2022	A2E0842-09	Lead	ND	0.2	15	ppb
168-DF-3096-A-003-A	Hallway (Classroom 7)	5/20/2022	5/31/2022	A2E0842-01	Lead	ND	0.2	15	ppb
168-DF-3099-A-003-A	Hallway (Classroom 205)	5/20/2022	5/31/2022	A2E0842-07	Lead	ND	0.2	15	ppb
168-DF-6259-A-003-A	Hallway (Library 003)	5/20/2022	5/31/2022	A2E0842-06	Lead	ND	0.2	15	ppb
168-DF-6260-N/A-003-A	Kitchen	5/20/2022	5/31/2022	A2E0842-04	Lead	0.362	0.2	15	ppb
168-DF-6261-A-003-A	Cafeteria	5/20/2022	5/31/2022	A2E0842-03	Lead	ND	0.2	15	ppb
168-DF-6262-N/A-003-A	Staff Room	5/20/2022	5/31/2022	A2E0842-05	Lead	0.339	0.2	15	ppb
168-DF-6264-N/A-003-A	Office 108A	5/20/2022	5/31/2022	A2E0842-02	Lead	2.33	0.2	15	ppb
168-DF-6265-A-003-A	Outside Portable 3	5/20/2022	5/31/2022	A2E0842-08	Lead	0.252	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1