

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Marshall Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
220 DF5271 A 006 A	Weight room	7/12/2022	7/14/2022	A2G0387 01	Lead	0.773	0.200	15	ppb
220 DF5274 A 006 A	Gym (G4)	7/12/2022	7/14/2022	A2G0387 02	Lead	0.660	0.200	15	ppb
220 DF5280 A 006 A	Gym A33	7/12/2022	7/14/2022	A2G0387 03	Lead	0.539	0.200	15	ppb
220 DF5283 A 006 A	Gym A34	7/12/2022	7/14/2022	A2G0387 04	Lead	0.807	0.200	15	ppb

*OHA Action Level = 15ppb