

Portland Public School s
Lead Water Sampling Results
Initial Flush Sample Data
Chief Joseph - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
148 DF2983N/A 005 A	StaffRoom	6/7/2022	6/16/2022	A2F024303	Lead	1.16	0.200	15	ppb
148 DF2989A 005 A	Cafeteria	6/7/2022	6/16/2022	A2F024304	Lead	ND	0.200	15	ppb
148 DF2991 A 005 A	Hallway(Principal)	6/7/2022	6/16/2022	A2F024302	Lead	ND	0.200	15	ppb
148 DF2998 A 005 A	Hallway(Classroom10)	6/7/2022	6/16/2022	A2F024301	Lead	0.655	0.200	15	ppb
148 DF6159N/A 005 A	Kitchen	6/7/2022	6/16/2022	A2F024305	Lead	ND	0.200	15	ppb
148 DF6160N/A 005 A	HealthRoom	6/7/2022	6/16/2022	A2F024306	Lead	1.59	0.200	15	ppb

*OHAActionLevel= 15ppb