

246 DF 3810 A 005 A	Clinical Office 2	8/2/2022	8/9/2022	A2H0127 03	Lead	0.275	0.200	15	ppb
246 DF 3813 A 005 A	Therapy Room 3	8/2/2022	8/9/2022	A2H0127 04	Lead	0.649	0.222	15	ppb
246 DF 3819 A 005 A	Classroom 9	8/2/2022	8/8/2022	A2H0127 01	Lead	ND	0.222	15	ppb
246 DF 3825 A 005 A	Classroom 8	8/2/2022	8/10/2022	A2H0127 05	Lead	1.07	0.200	15	ppb
246 DF 3827 A 005 A	Health Room	8/2/2022	8/8/2022	A2H0127 06	Lead	0.424	0.200	15	ppb
246 DF 6117 NA 005 A	Kitchen	8/2/2022	8/8/2022	A2H0127 02	Lead	7.39	0.222	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1