

305 DF 1307 A 004 A	Outside (Portable '3)	8/4/2022	8/12/2022	A2H0201 01RE1	Lead	0.703	0.2	15	ppb
305 DF 1310 A 004 A	Hallway (Portable '1)	8/4/2022	8/12/2022	A2H0201 02RE1	Lead	ND	0.2	15	ppb
305 DF 6121 NA 004 A	Portable '2	8/4/2022	8/12/2022	A2H0201 03RE1	Lead	2.19	0.2	15	ppb
305 DF 6127 NA 004 A	Office	8/4/2022	8/12/2022	A2H0201 04RE1	Lead	ND	0.2	15	ppb
305 DF 6128 NA 004 A	Kitchen	8/4/2022	8/12/2022	A2H0201 05RE1	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

\*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

Page 1 of 1