

Portland Public Schools
 Lead Water Sampling Results
 Initial Flush Sample Data
 King Site - Test 10

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
262DF6129NA010A	StaffRoom(Annex)	8/4/2022	8/8/2022	A2H018102	Lead	0.252	0.200	15	ppb
262DF6130NA010A	AnnexSpeciaEd.Classroom	8/4/2022	8/8/2022	A2H018103	Lead	ND	0.200	15	ppb
262DF6131A010A	Hallway(Annex)	8/4/2022	8/8/2022	A2H018101	Lead	1.11	0.200	15	ppb

*OHAActionLevel= 15ppb