

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Marshall Site - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
220 DF 5270 A 007 A	Hallway (Classroom B 24)	8/2/2022	8/8/2022	A2H0128 01	Lead	ND	0.200	15	ppb
220 DF 5276 A 007 A	Hallway (Auditorium)	8/2/2022	8/8/2022	A2H0128 02	Lead	ND	0.200	15	ppb
220 DF 5282 A 007 A	Hallway (Wood Shop A2)	8/2/2022	8/8/2022	A2H0128 03	Lead	ND	0.200	15	ppb
220 DF 5289 A 007 A	Cafeteria	8/2/2022	8/10/2022	A2H0128 04	Lead	ND	0.222	15	ppb
220 DF 5293 A 007 A	Hallway (Drafting C 38)	8/2/2022	8/8/2022	A2H0128 05	Lead	ND	0.200	15	ppb
220 DF 5354 A 007 A	Hallway (Physics C 10)	8/2/2022	8/8/2022	A2H0128 06	Lead	ND	0.200	15	ppb
220 DF 6104 NA 007 A	Kitchen	8/2/2022	8/8/2022	A2H0128 07	Lead	0.390	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb