

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sunnyside Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
191 DF 3788 A 006 A	Hallway (105)	9/28/2022	9/29/2022	A2I0877 01	Lead	ND	0.200	15	ppb
191 DF 3792 A 006 A	Hallway (207)	9/28/2022	9/29/2022	A2I0877 02	Lead	ND	0.200	15	ppb
191 DF5928 NA 006 A	Staff Room	9/28/2022	9/29/2022	A2I0877 04	Lead	1.18	0.222	15	ppb
191 DF 5931 A 006 A	Hallway (110)	9/28/2022	9/29/2022	A2I0877 03	Lead	ND	0.200	15	ppb

*OHA Action Level = 15ppb