

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Sunnyside Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
191 DF3806A 005 A	Hallway(204)	9/16/2022	9/19/2022	A21052801	Lead	ND	0.200	15	ppb
191 DF3835A 005 A	Hallway(104)	9/16/2022	9/19/2022	A21052802	Lead	ND	0.200	15	ppb
191 DF5929A 005 A	Cafeteria	9/16/2022	9/19/2022	A21052803	Lead	ND	0.200	15	ppb
191 DF5930NA 005 A	Kitchen	9/16/2022	9/19/2022	A21052804	Lead	0.426	0.200	15	ppb
191 DF5932NA 005 A	StaffRoom	9/16/2022	9/19/2022	A21052805	Lead	0.610	0.200	15	ppb

\*OHAActionLevel= 15ppb